WT-L-9000PVC,WT-L-12000 (Long Distance)

Features

- Simple Calibration
- Non-Contact
- Temperature Comp.
- Analog 4-20mA Output
- Sensitivity Control
- Easy Installation
- Self-Contained LED Indicator Quick Disconnect Affordability Microprocessor Design



These self-contained Ultrasonic Sensors provide level control of both liquid and bulk materials. This gives the user a viable alternative to bubblers. floats, capacitance probes and pressure transmitters. With sensing ranges of 9144 and 12192mm respectively many tanksare within reach. Their incorporation of a microprocessor designmakes it possible toachieve signal conditioning This gives the sensortheability to process the returnultrasonic echo and distinguishbetween false targets and real tar-gets.

incorporation of a With the microcontroller into the design of the WT-L-3000PVC and WT-L-4000 many of the common problems facing long range sensing applications have been overcome. Software was then written to optimize the performance characteristics of the sensors. The artificial intelligence analyzes and conditions the return ultrasonic echo. This process filters out any false echoes and electrical noise. An additional task that the microcontroller does is temperature compensation.

The following is a brief list of features for the WT-L- HOW TO CALIBRATE 3000PVC and WT-L-4000.

Method One (and possibly the most direct way to calibrate SIMPLE CALIBRATION: The sensing window can be the sensing range) is as follows (see figure B): adjusted by using one of three easy methods. NOTE: When the sensors are powered up and the control lines not Step 1: Tie the Red/Yel wire (20mA control line) and the used, they are factory preset to maximum range.

NON-CONTACT: The use of ultrasonic sound to measure distance means that the sensor does not need to come in contact with the target.

TEMPERATURE COMPENSATED: This is accomplished by means of a temperature probe that is built into the transducer head.

ANALOG OUTPUT: These sensors provide a 4-20mA analog output that is proportional to the changing distance. This output can be inverted.

NOTE: When completed, the two control lines should SENSITIVITY CONTROL: This enables the gain of the remain tied together. To change the window, disconnect sensor to be adjusted to work best in different tanks and on these two wires for one second and then reconnect them. different materials. Then repeat steps 2 and 3. The far point should always be programmed first, then the near point.

EASY INSTALLATION: Both of these sensors are contained in a standard 30mm housing. They come with two jam-nuts for simple mounting.

SELF-CONTAINED: There are no remote boxes to moun with these sensors. All necessary electronics are con tained within the sensor.

LED INDICATOR: This indicates the detect state of the sensor as well as the strength of the return echo. This feature helps to insure proper alignment during installation

AFFORDABILITY: These sensors were designed to be cost competitive and to solve applications.

MICROPROCESSOR DESIGN: The incorporation of microprocessor allowed software to be written to solve many of the common problems that needed to be overcome **Open:** This indicates that the control line is not tied to with long range applications. anything. It is left floating.





- Red/Blue wire (4mA control line) together.
- Step 2: With the material level at the 4mA point, usually the low level, connect these lines to ground (Green wire) for one second.
- Step 3: With the material level at the 20mA point, usually the high level, connect these lines to plus (Red wire) for one second.
- The sensor is now calibrated and will generate the analog 4-20mA output between these two points.
- Method Two calibrates the sensors by using the following charts (see figure C): (Min. sensing distance: 610mm)

.+	WT	-L-3000P	VC	WT-L-4000		
1L)-	Max. Sensing Window (mm)	Red/Blue Wire	Red/Yel Wire	Max. Sensing Window (mm)	Red/Blue Wire	Red/Yel Wire
	9144	OPEN	OPEN	12192	OPEN	OPEN
е	8229	OPEN	LOW	10972	OPEN	LOW
S	7315	OPEN	HIGH	9753	OPEN	HIGH
۱.	6400	LOW	OPEN	8534	LOW	OPEN
	5486	LOW	LOW	7315	LOW	LOW
е	4572	LOW	HIGH	6096	LOW	HIGH
	3657	HIGH	OPEN	4876	HIGH	OPEN
	2743	HIGH	LOW	3657	HIGH	LOW
а	1828	HIGH	HIGH	2438	HIGH	HIGH
۵						

High: The control line is tied to plus (Red Wire).

Low: The control line is tied to ground (Green Wire).

When using these charts to calibrate the sensors the analog output will occur over the full range of the selected sensing window. The 20mA will be at the near distance and the 4mA will be at the far distance.

One advantage of calibrating the sensors this way is that there is no need to fill the tank to the high and low limits. Another advantage is that once the sensor is installed there is no need to go back to it to program. This can be done at a remote location at the end of the sensor's cable.



Method Three calibrates the sensors by using resistors tied to the control lines (see figure D). These resistors are installed between the control lines and ground (green wire). The following resistance formula applies for distance:

1Kohm = 304.8mm.

For example if a range of 1524 to 4572mm is desired with an analog output of 20mA at 1524mm, and 4mA at 4572mm, the following resistor values should be selected:

4572mm = 15Kohm resistor tied to 4mA control line (Red/Blue) 1524mm = 5Kohm resistor tied to 20mA control line (Red/Yellow)

The output will now start at 1524mm 20mA and decrease withdistance to 4572mm 4mA. The output can be scaled in the opposite direction by reversing the values:

1524mm = 5Kohm resistor tied to 4mA control line (Red/Blue) 4572mm = 15Kohm resistor tied to 20mA control line (Red/Yel)

The output now starts at 1524mm 4mA and increases with distance to 4572mm 20mA.

Potentiometers can be used in place of fixed resistors and then the proper distances can be dialed in.

The advantage with this method, as with the second way of calibrating, is that the tank does not need to be filled to its high and low limits during setup. In addition these set points can be adjusted at a later time without going to the top of the tank.

HOW TO USE THE GAIN CONTROL

The WT-L-3000PVC and WT-L-4000 sensors provide the QUICK DISCONNECT CONNECTOR user with gain control. This is controlled by the Red/White wire (see figure E). When this wire is left open (floating) the sensors are operating at their maximum sensitivity. The sensor's gain can be reduced by doing the following:

Install a 100Kohm potentiometer or a fixed value resistor across the gain control line (Red/White wire) and ground (Green wire). With the potentiometer set at 100Kohm, the gain or sensitivity of the sensor is at its maximum. When the potentiometer is set at 75Kohm, the sensitivity is 75% of full gain. If the potentiometer is turned all the way down which is equivalent to shorting the gain wire to ground, the sensor is at minimum sensitivity.

The sensitivity/gain control allows the sensor to be adjusted to work best in different tanks and on different materials. This control does not need to be used. If the sensor is installed and works well with full sensitivity there is no need to reduce the gain. However if the sensor is installed and it seems to be detecting something other then the desired target, the gain can be reduced to see if the false target disappears.

LED INDICATOR

The LED is located at the back of the sensor. It provides by way of color various indication as to the sensor's functions. Its primary purpose is to insure proper alignment during installation. The following colors indicate:

Green: The sensor has power and is in the no-detect state.

Yellow: The sensor has detected a target but is receiving a weak signal. It may be that the sensor is not properly aligned to the material or that the target is providing a weak return echo.

Red: This indicates that the sensor is detecting the target. The brighter the shade of red the stronger the return echo. This indicates the sensor is properly aligned and the target is providing a good reflective surface.

NOTE: It may not always be possible to get a bright red signal. This is because various materials will have different reflectivity characteristics. However, as long as the sensor stays in the yellow to red state, enough return signal is being received and the sensor will function properly.

ANALOG OUTUT

The WT-L-3000PVC and WT-L-4000 provide an analog current output of 4-20mA. This output is proportional to the changing distance that has been programmed. The output load rating of the sensors are 0 to 500 ohms.

At the rear of the sensor, there is a water tight quick disconnect connector. This allows the sensor to be easily removed from the tank should this be desired.

MICROPROCESSOR DESIGN

The WT-L-3000PVC and WT-L-4000 long range ultrasonic sensors incorporate a high speed microcontroller/microprocessor. Software was then written to optimize the performance characteristics of the sensors. This artifical intelligence analyzes and conditions the return ultrasonic echo. This process filters out any false echos and electrical noise. An additional task that the microcontroller does is temperature compensation. This allows the sensor to have a more accurate output over varying temperature ranges. Thus with the incorporation of a microcontroller many of the common problems facing long range sensing applications have been overcome.

Specifications:

Operational Range: WT-L-3000PVC WT-L-4000	Adjustable 609 to 9144mm Adjustable 609 to 12192mm				
Power Input:	20 - 30 VDC Reverse Polarity Protected				
Input Current:	125 Milliamps				
Ambient Temperature	-20°C to 60°C or -5°F to 140°F				
Humidity	0% - 95% Non-Condensing				
Enclosure:	WT-L-3000PVC: Epoxy filled PVC housing with PVC sensing face. WT-L-4000: Epoxy filled PVC housing with Glass Reinforced Epoxy sensing face.				
Outputs	Current Sourcing Analog Output 4 - 20mA Inverted & Non-Inverted Short Circuit Protected				
Transducer Frequency:	WT-L-3000PVC WT-L-4000 38Khz 41Khz				
Transmit Time:	This equals the sensors maximum distance x 10mSec. For example if the maximum programmed distance is 10' the transmit time is 100mSec.				
Weight:	425g				
RED 20-30VDC GREEN GROUND RED/BLK 4-20MA RED/WHT GAIN CON RED/BLU 4mA CONT	RED 20-30VDC GREEN GROUND RED/BLK 4-20MA RED/BLK 4-20MA RED/WHT GAIN CONTROL TIE HIGH, LOW, OR OPEN RED/YEL 20MA CONTROL TIE HIGH LOW OR OPEN				

Figure:

A-Installation/BeamSpread B-Wiring Diag. for programming method#1 C-Wiring Diag. for programming method #2 D-Wiring Diag. for programming method #3 E-Wiring Diag. for gain control F-ConnectorDiagram(MaleView) **G-Mounting Dimensions**



"QD" cables are sold separately.

Fig. B

PART NUMBER	RANGE	
WT-L-9000PVC	609 to 9144mm	PVC
WT-L-12000	609 to 12192mm	PVC
5000127-2		1828
5000127-4		4876



DESCRIPTION

Housing with PVC Sensing Face

Housing with Glass Reinforced Epoxy Sensing Face

3mm Cable with "QD"

6mm Cable with "QD"